



453 6453 1645

NATIONAL BUREAU OF STANDARDS REPORT

NBS PROJECT

NBS REPORT

1002-30-4073

July 8, 1959

0450

Birth
Progress Report
on the
Mechanism of Fire Ignition and Extinguishment
by

R. C. Grolts

Covering period 1 January to 30 June 1959

for
Bureau of Ships
Department of the Navy
Code 538
Index Number NS-163-001

IMPORTANT NOTICE

NATIONAL BUREAU OF STANDARDS
intended for use within the
to additional evaluation and
listing of this Report, either
the Office of the Director, or
however, by the Government
to reproduce additional copies

Approved for public release by the
Director of the National Institute of
Standards and Technology (NIST)
on October 9, 2015.

progress accounting documents
ormally published it is subjected
g, reproduction, or open-literature
ission is obtained in writing from
Such permission is not needed,
y prepared if that agency wishes



U. S. DEPARTMENT OF COMMERCE
NATIONAL BUREAU OF STANDARDS

1. THE BOARD OF DIRECTORS OF THE COMPANY

2. THE BOARD OF DIRECTORS OF THE COMPANY

3. THE BOARD OF DIRECTORS OF THE COMPANY

4. THE BOARD OF DIRECTORS OF THE COMPANY

5. THE BOARD OF DIRECTORS OF THE COMPANY

6. THE BOARD OF DIRECTORS OF THE COMPANY

7. THE BOARD OF DIRECTORS OF THE COMPANY

8. THE BOARD OF DIRECTORS OF THE COMPANY

9. THE BOARD OF DIRECTORS OF THE COMPANY

10. THE BOARD OF DIRECTORS OF THE COMPANY

11. THE BOARD OF DIRECTORS OF THE COMPANY

12. THE BOARD OF DIRECTORS OF THE COMPANY

13. THE BOARD OF DIRECTORS OF THE COMPANY

14. THE BOARD OF DIRECTORS OF THE COMPANY

15. THE BOARD OF DIRECTORS OF THE COMPANY

16. THE BOARD OF DIRECTORS OF THE COMPANY

17. THE BOARD OF DIRECTORS OF THE COMPANY

18. THE BOARD OF DIRECTORS OF THE COMPANY

19. THE BOARD OF DIRECTORS OF THE COMPANY

20. THE BOARD OF DIRECTORS OF THE COMPANY

21. THE BOARD OF DIRECTORS OF THE COMPANY

22. THE BOARD OF DIRECTORS OF THE COMPANY

23. THE BOARD OF DIRECTORS OF THE COMPANY

24. THE BOARD OF DIRECTORS OF THE COMPANY

25. THE BOARD OF DIRECTORS OF THE COMPANY

MECHANISMS OF FIRE IGNITION AND EXTINGUISHMENT

1. SUMMARY

Scaling factors have been determined relating the efficiency of dry powders of varying chemical composition in extinguishing fires of n-heptane in 1-, 6-, and 10-in. and 2-ft diameter containers. The same factors appear to apply equally well to the results on fires up to 13 ft² reported by Neill. A mechanism of inhibition based on ionic reactions is outlined and its application to the study of dry powders is discussed.

2. EXTINGUISHMENT BY POWDERS

The consolidation of results into final form, as mentioned in the Fifth Progress Report, showed the necessity for filling in some additional information and it was thought to be desirable to hold up the report for incorporation of results on 2-ft diameter fires. The final report will show that the rate of application of dry powder of a particular chemical composition is almost proportional to the area of the fire. Sodium bicarbonate, potassium bicarbonate, potassium oxalate and potassium iodide were studied, each giving a different efficiency, but all related in very nearly the same way to the area of the test fire. The results of R. R. Neill, Naval Research Laboratory Report 5183, on test fires up to 13 x 13 ft can be plotted on the same curves. The significance of this work is that comparative tests of dry powder extinguishing agents can now be made on small laboratory test fires with some degree of confidence that the results will also apply to full-scale fires.

3. THERMAL REACTIONS

The work on mechanisms of extinguishment started on this project was transferred to an NBS project at the beginning of last fiscal year. A paper has been submitted to the NBS Editorial Committee covering the results of some preliminary studies of ionic processes in flames. Some of the conclusions, without the supporting evidence, are presented here as background for new work to be undertaken on this project. This paper presents evidence that, in a flame, the following three ionic processes are important:



where e^- = an electron

MECHANISMS OF IONIC INHIBITION AND EXTINGUISHMENT

1. SUMMARY

Leading factors have been determined relating the efficiency of dry powders of varying chemical composition in extinguishing fires of n-heptane in 1-, 5-, and 10-in. and 2-1/2 diameter containers. The same factors appear to apply equally well to the results on fires up to 15 ft² reported by Helli. A mechanism of inhibition based on ionic reactions is outlined and its application to the study of dry powders is discussed.

2. EXTINGUISHMENT BY POWDERS

The consolidation of results into final form, as mentioned in the fifth progress report, showed the necessity for filling in some additional information and it was thought to be desirable to hold up the report for incorporation of results on 2-1/2 diameter fires. The final report will show that the rate of application of dry powder of a particular chemical composition is almost proportional to the area of the fire. Sodium bicarbonate, potassium bicarbonate, potassium oxalate and potassium iodide were studied, each giving a different efficiency, but all related in very nearly the same way to the area of the test fire. The results of H. M. Helli, Naval Research Laboratory Report 2185, on test fires up to 15 x 15 ft can be plotted on the same curves. The significance of this work is that comparative tests of dry powder extinguishing agents can now be made on small laboratory test fires with some degree of confidence that the results will also apply to full-scale fires.

3. IONIC REACTIONS

The work on mechanisms of extinguishment started on this project was transferred to an NBS project at the beginning of last fiscal year. A paper has been submitted to the National Committee covering the results of some preliminary studies of ionic processes in flames. Some of the conclusions, without the supporting evidence, are presented here as background for new work to be undertaken on this project. This paper presents evidence that, in a flame, the following three ionic processes are important:



where e^- = an electron

The indications are that, in lean flames, reaction (1) is rate controlling, while in diffusion and rich flames, reaction (2) and the diffusion of oxygen into the reaction zone are rate controlling. Reaction (3) is rapid under any conditions.

Inhibition can be accomplished, in the proposed mechanism, by interference with any of the three reactions. It is shown that compounds which have a large cross section for capture of electrons of the range of energies found in flames are also effective extinguishing agents. The relationship between the effectiveness of a dry powder and its surface area points to an adsorption phenomenon of some sort. The fact that dry powders emerging from a flame are charged negatively points to adsorption of either electrons or O_2^- ions.

An investigation is being started on this project of the number of charges acquired by dry powder particles and its relationship to chemical constitution. It is also of interest to determine whether the charges are retained more or less permanently, and to find an explanation for the observed fact that powders having low decomposition temperatures seem to be more effective extinguishing agents. This work is not much beyond the planning stage at the present time, but is expected to be actively prosecuted at an early date.



R152 1/3 Series
File Folders



www.pendaflex.com 10% P4
MADE IN USA

